

# Emission Test Certificate

Monday April 14<sup>th</sup>, 2008

Supplier: Wharington International Pty Ltd

48 - 50 Hargreaves Street

Huntingdale Victoria 3166

Sample Description: RECOPOL™ Recycled Resin

Date Tested: April 2008.

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

## RECOPOL™

Total Volatile Organic Compound Emission Rate: <0.02 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.25 mg/m<sup>3</sup> as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV080313